



# THE COMMISSIONERS OF THURMONT

Division of Public Works  
10 Frederick Road  
P.O. Box 17  
Thurmont, Maryland 21788

Thurmont Water Department

September 8, 2025

2<sup>nd</sup> Quarter PFAs Sampling

Sampling Results For EPA's Fifth Unregulated Contaminant Rule (UCMR 5)

Wells No. 3,4,9

Well No. 8

Sample Date : 7/14/25

Sample Date : 7/14/25

PFOS – 12 ppt

PFOS – 48 ppt

PFOA – 13 ppt

PFOA – 15 ppt

Well No. 7

Sample Date : 7/14/25

PFOS – 25 ppt

PFOA – 8.4 ppt

Harold Lawson

Director of Public Works

Town of Thurmont

